

WASTE WATER PLANTS IN THE TANA RIVER SYSTEM- INFORMATION SHEET

Name of waste water plant: Skiippagurra waste water plant

Owner: Tana municipality

Operator: Tana municipality

Located in (municipality): Tana and (country): Norway



Basic information on treatment, discharge and permit

Year of construction: 2013

Type of treatment: Chemical- biological treatment

Location of outlet (coordinates and UTM code): X= 7784930, Y= 546350. UTM code 35.

Max. allowed discharge in permit (PE): 600 PE

Discharge per 2017 in PE: 140 PE

Number of households connected: 28 households.

Type of industry connected: None.

Annual discharge of phosphorous (P)(kg/year): 8,9

Annual discharge of nitrogen (N)(kg/year): 262,8

Annual discharge of organic matter (BOF/BOD7) (kg/year): 22,3 BOF5 kg/year

Suspended solids (SS/STS) (kg/year): 112,3